

F6 Maintenance Checking

Recommended Maintenance Checking Procedure for Ecoglo Escape Route Products:

6 Monthly Maintenance Check *(to be carried out by the Owner or their appointed agent)* COMPLETED

- All products are still configured as at installation and there is no material damage to any of the products.
- All products are clean from general dust build up and any other specific obscuring deposits.
- All products are clearly visible and have not been covered up by carpet or other materials.
- All products mark a clear path and have not been obstructed by physical hazards such as trolleys, machinery, partitions, etc.
- All products can be used to provide clear escape path marking and there has been no change to the configuration of the building which renders the escape path unusable.
- All lights checked that the positions have not altered from design.
- All lights are in working order and clean.
- All automated lighting control systems are operational as per design

Annual Inspection *(to be carried out by an IQP)* COMPLETED

- All products are still configured as at installation and there is no material damage to any of the products.
- All products are clean from general dust build up and any other specific obscuring deposits.
- All products are clearly visible and have not been covered up by carpet or other materials.
- All products mark a clear path and have not been obstructed by physical hazards such as trolleys, machinery, partitions, etc.
- All products can be used to provide clear escape path marking and there has been no change to the configuration of the building which renders the escape path unusable.
- All lights checked that the positions have not altered from design.
- All lights are in working order and clean.
- All automated lighting control systems are operational as per design



Ecoglo International Limited

PO Box 7698, Sydenham 8240,
77 Kingsley Street, Sydenham 8023
Christchurch
New Zealand

Phone: 03 348 3781
Fax: 03 343 6821
Email: info@ecoglo.com
www.ecoglo.co.nz